

Feb 2015

## Honeywell Novar XIO Remote I/O Protocol Implementation Conformance Statement (PICS)

Topic: BACnet Protocol Implementation Conformance Statement (PICS)  
Date: Feb 2015  
Version: 2.0  
Applicable Products: XIO Remote I/O - 8 Current Transformer Inputs  
Author: Toni Liu

This document contains Honeywell proprietary information. Information contained herein is to be used solely for the purpose submitted, and no part of this document or its contents shall be reproduced, published, or disclosed to a third party without the express permission of Honeywell International Sàrl.

HONEYWELL DISCLAIMS THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PURPOSE AND MAKES NO EXPRESS WARRANTIES EXCEPT AS MAY BE STATED IN ITS WRITTEN AGREEMENT WITH AND FOR ITS CUSTOMER.

In no event is Honeywell liable to anyone for any direct, special, or consequential damages. The information and specification in this document are subject to change without notice.

# Novar XIO Remote I/O Controller

## Annex A - Protocol Implementation Conformance Statement

**Date:** 9<sup>th</sup> Feb 2015

**Vendor ID:** 333

**Vendor Name:** Novar

**Product Name:** XIO Remote I/O - 8 Current Transformer Inputs

**Product Model Number:** xio.80CT

**Applications Software Version:** N/A

**Firmware Revision:** 1.2.3

**BACnet Protocol Revision:** 10

### Product Description and Intended Use:

While the xio family is intended to meet the needs of Novar's multi-site refrigeration customers, the xio family is in essence general-purpose, I/O modules; therefore, HVAC and lighting control customers that require/demand small-footprint, open-protocol, expandable I/O modules that are hot-swappable and DIN-rail-mountable will be able to take advantage of all of xio's new features. This I/O product has 8 Current Transformer Inputs.

### BACnet Standardized Device Profile (Annex L):

- BACnet Operator Workstation (B-OWS)
- BACnet Advanced Operator Workstation (B-AWS)
- BACnet Operator Display (B-OD)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

### BACnet Interoperability Building Blocks Supported (Annex K):

<b>Data Sharing</b>	Read Property-B	DS-RP-B
	Read Property Multiple-B	DS-RPM-B
	Write Property-B	DS-WP-B
<b>Device &amp; Network Management</b>	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	Device Communication Control-B	DM-DCC-B
	Reinitialize Device-B	DM-RD-B

### Following device binding methods Supported by the controller

- Send Who-Is, receive I-Am (BIBB DM-DDB-A)
- Receive Who-Is, send I-Am (BIBB DM-DDB-B)
- Send Who-Has, receive I-Have (BIBB DM-DOB-A)
- Receive Who-Has, send I-Have (BIBB DM-DOB-B)
- Manual configuration of recipient device's network number and MAC address
- None of the above

### Segmentation Capability:

Able to transmit segmented messages  no  no Window Size \_\_\_\_  
 Able to receive segmented messages  no  no Window Size \_\_\_\_

**Data Link Layer Options:**

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s)
- MS/TP master (Clause 9), baud rate(s): 9.6k, 19.2k, 38.4k, 57.6k, 76.8k bps
- MS/TP slave (Clause 9), baud rate(s): 9.6k, 19.2k, 38.4k, 57.6k, 76.8k bps
- Point-To-Point, EIA 232 (Clause 10), baud rate(s):
- Point-To-Point, modem, (Clause 10), baud rate(s):
- LonTalk, (Clause 11), medium:
- Other:

**Device Address Binding:**

Is static device binding supported?  
 (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.)  
 Yes   
 No

**Networking Options:**

- Router, Clause 6 - BACnet IP (Annex J)
- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)  
 Does the BBMD support registrations by Foreign Devices?   
 Yes   
 No

**Character Sets Supported:**

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- UTF-8
- IBM™/Microsoft™ DBCS
- JIS C 6226
- ISO 10646 (UCS-4)
- ISO 10646 (UCS-2)
- ISO 8859-1

**Standard Object Types Supported:**

	Object supported	Object dynamically creatable	Object dynamically deletable
ANALOG_INPUT	Y	N	N
ANALOG_OUTPUT	N	N	N

ANALOG_VALUE	Y	N	N
AVERAGING	N	N	N
BINARY_INPUT	N	N	N
BINARY_OUTPUT	N	N	N
BINARY_VALUE	Y	N	N
CALENDAR	N	N	N
COMMAND	N	N	N
DEVICE	Y	N	N
EVENT_ENROLLMENT	N	N	N
FILE	Y	N	N
GROUP	N	N	N
LOOP	N	N	N
LIFE_SAFETY_DEVICE	N	N	N
LIFE_SAFETY_ZONE	N	N	N
MULTISTATE_INPUT	N	N	N
MULTISTATE_OUTPUT	N	N	N
MULTISTATE_VALUE	N	N	N
NOTIFICATION_CLASS	N	N	N
PROGRAM	Y	N	N
SCHEDULE	N	N	N
TRENDLOG	N	N	N
ACCUMULATOR	N	N	N
PULSE_CONVERTER	N	N	N

**Standard Objects and Properties Supported:**

**Analog Input Object:**

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	OBJECT_NAME
OBJECT_TYPE	
PRESENT_VALUE	PRESENT_VALUE
STATUS_FLAGS	
EVENT_STATE	
OUT_OF_SERVICE	OUT_OF_SERVICE
UNITS	UNITS
DESCRIPTION	

**Analog Value Object:**

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
PRESENT_VALUE	PRESENT_VALUE
STATUS_FLAGS	
EVENT_STATE	
OUT_OF_SERVICE	OUT_OF_SERVICE
UNITS	
PRIORITY_ARRAY	
RELINQUISH_DEFAULT	
DESCRIPTION	

STATUS COMMUNICATION LOSS(6067)	STATUS COMMUNICATION LOSS(6067)
---------------------------------	---------------------------------

**Binary Value Object:**

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
PRESENT_VALUE	PRESENT_VALUE
STATUS_FLAGS	
EVENT_STATE	
OUT_OF_SERVICE	

**Device Object:**

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	OBJECT_IDENTIFIER
OBJECT_NAME	OBJECT_NAME
OBJECT_TYPE	
SYSTEM_STATUS	
VENDOR_NAME	
VENDOR_IDENTIFIRE	
MODEL_NAME	
FIRMWARE_REVISION	
APPLICATION_SOFTWARE_VERSION	
PROTOCOL_VERSION	
PROTOCOL_REVISION	
PROTOCOL_SERVICES_SUPPORTED	
PROTOCOL_OBJECT_TYPES_SUPPORTED	
OBJECT_LIST	
MAX_APDU_LENGTH_ACCEPTED	
SEGMENTATION_SUPPORTED	
APDU_TIMEOUT	
NUMBER_OF_APDU_RETRIES	
DEVICE_ADDRESS_BINDING	
DATABASE_REVISION	
MAX_MASTERS	MAX_MASTERS
MAX_INFO_FRAMES	
DESCRIPTION	DESCRIPTION
LOCATION	LOCATION
BAUD_RATE(6060)	
HEART_BEAT(6066)	HEART_BEAT(6066)

**File Object:**

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
FILE_TYPE	
FILE_SIZE	
MODIFICATION_DATE	
ARCHIVE	ARCHIEVE
READ_ONLY	

FILE_ACCESS_METHOD	
DESCRIPTION	

**Program Object:**

Readable Properties	Writable Properties
OBJECT_IDENTIFIER	
OBJECT_NAME	
OBJECT_TYPE	
PROGRAM_STATE	
PROGRAM_CHANGE	PROGRAM_CHANGE
STATUS_FLAGS	
OUT_OF_SERVICE	OUT_OF_SERVICE
REASON_FOR_HALT	
DESCRIPTION_OF_HALT	
DESCRIPTION	